



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO. GYJ11.1602

This is to certify that the product

Magnetostrictive Level Gauge

manufactured by

FAFNIR GmbH

(Address: Bahrenfelder Strasse 19, D - 22765 Hamburg, Germany)

which model is

TORRIX Ex Series

Ex marking

Ex ia II CT1~T4 Ga

Ex ia II CT1~T6 Gb

product standard

/

drawing number

XF 014 100/120/140/160

has been inspected and certified by NEPSI, and that it conforms to

GB3836.1 - 2010、GB3836.4 - 2010

This Approval shall remain in force until 2017.03.19

Remarks

1. Special requirements for safe use specified in the attachment to this certificate.
2. Intrinsically safe parameters: See attachment to this certificate.

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2012.03.20

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.