

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 1112003-E233311

ISSUE DATE: 11-11-2003

Page 1 of 2

Issued to: PR Electronics A/S
Lerbakken 10
8410 Rønde, Denmark

Report Reference: E233311, November 7th & 11th, 2003


This is to Certify that
representative samples of: Associated apparatus, nonhazardous locations:
Type 5202B & 5203B.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: UL913 Process Control Equipment for use in hazardous locations.
The products have also been investigated to United States Standard UL 508,
"Industrial Control Equipment". The evaluation to this standard is done in file
E231911 vol 1, sec. 2, issued 2003-09-19.


Additional Information: See Addendum 1

Only those products bearing the UL Listing Mark for the US and Canada should be considered as
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for
US and Canada.


The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word
"LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the
appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:


Klaus M Hansen
Demko A/S

Review Engineer:


Steen Christensen
Demko A/S

Pursuant to the Certification and Registration Agreement between Demko A/S and Underwriters Laboratories Inc. ("UL"), UL hereby accepts
and issues this Certificate of Compliance. For questions in Denmark, you may call +45 4485 6565.

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500



An Affiliate of
**Underwriters
Laboratories Inc.®**

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 11112003-E233311

Page 2 of 2

ISSUE DATE: 11-11-2003


This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Vol 1, sec 4


Pulse Isolator Type 5202B followed by 1, 2 or 4 providing intrinsically safe outputs for use in hazardous locations Class I Division 1, Group A, B, C and D, Class I Zone 0 and 1, Group IIC, Class II, Division 1, group E, F and G when installed in accordance with control drawing no. 5002QU01.

Vol. 1, sec. 5

Ex Solenoid / Alarm Driver Type 5203B followed by 1, 2 or 3 followed by F, H or I followed by 1 or 2, providing intrinsically safe outputs for use in hazardous locations Class I, Division 1, Group A, B, C and D, Class I Zone 0 and 1, Group IIC, Class II, Division 1, group E, F and G when installed in accordance with control drawing no. 5203QU01



Engineer: 
Klaus M Hansen

Review Engineer: 
Steen Christensen

Pursuant to the Certification and Registration Agreement between Demko A/S and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance. For questions in Denmark, you may call +45 4485 6565.